

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

No. 1715

Date 15.06.24

It is certified that an inspection team headed by Sri Dharmendra Kumar, Lab Assistant (Name of officers with designation) from Public Health Sub Division, Laheriasarai Darbhanga (Name of Department / office) inspected the SALFIA SCHOOL, Belwaganj, Laheriasarai, Darbhanga (Name & Address of the School) 11.06.2024 (Date of inspection) has safe drinking water Facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of one Year

Signature with seal---

Name:- Dilip Kumar Chaudhary

Designation:- Excutive Engineer

Name & Address of the office/ Department:-

P.H. Division, Darbhanga .

To

Principal

Salfia School

Laheriasarai, Darbhanga- 846004 (Bihar)

Faheen Hayat  
Principal  
Salfia School  
Laheriasarai, Darbhanga

**District Level water Testing Laboratory Darbhanga DLWTL**

Government of Bihar

Public Health Engineering Department

District Name: Darbhanga

Sample collected by . Md. Shatawaz

Sl. No.	Block	Village	Ward no	Location of Source	Parameters															Total Coli	Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As			
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
1	Nagar Nigim	Selwaganj Laheriasaral	37	Salfia School Darbhanga	7.64	NT	412	268	136	32	24.96	72	262	0.28	12	NT	0.8	0.001	(-v)		
Desirable limit					6.5	5.0	-	500	200	75	30	250	200	0.3	45	25	1.0	0.01			
Permissible limit					8.5	10.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**		

*Fasheen Nayat*  
Principal  
Salfia School  
Laheriasarai, Darbhanga

*Md. Shatawaz*  
Chemist  
P.H Division Darbhanga  
11/01/24